



DENOMINAZIONE		Int. Aut. Differenz. Generale	Presa 1	Presa 2	Presa 3	Presa 4				
INTERRUTTORE	MAGNETOTERMICO:									
	POLI	In (A)	4	16						
	Ith (A)	Pdi (kA)	16	10						
	Im (A)		160							
PRESA	DIFFERENZIALE:									
	POLI	In (A)	4	25						
	Idn (A)		0,03							
	POLI PRESA:			3F+N+T - 16A	3F+T - 16A	F+N+T - 16A	F+N+T - 16A			
PRESA	INT. MAGNETOTERM.:									
	POLI	In (A)								
	Ith (A)	Pdi (kA)								
	Im (A)									
FUSIBILI:										
TIPO	In (A)									



via G. Galilei, 37/b 42027 Montecchio Emilia (RE)  
 tel. 0522.864644 fax 0522.866145  
 e-mail: info@friggeri.com web: www.friggeri.com

QUADRO TIPO:

PO-DN1120

POTENZA QUADRO:

8kW

MATRICOLA:

Nome file

PO-DN1120

Foglio  
1

Sg. Foglio  
/